



## **TECH BULLETIN**

**TECH BULLETIN NUMBER: 0109**

**DATE: August 2, 2004**

**Subject: AGS V2.2 software**

**Models affected: AGS**

Release V2.2 AGS software for 2 wire start generators. 2-wire start closes the start relay (pin 5&6) for 2 minutes then checks for B+ from generator. If B+ is available then the start relay stays closed for the run time setting. Generator stops after run time when start relay opens. All other AGS settings remain the same for 2-wire start.

Magnum Energy Inc.  
Tech Service Dept.