



TECH BULLETIN

TECH BULLETIN NUMBER: 0107

DATE: July 09, 2004

Subject: V0.7 Remote

Models affected: ME Series remote

In the AGS menu the "Test" mode stayed in test until the user selected "AGS Off". The "Test" mode now runs one cycle of test mode and automatically resets to "Off". Caret did not show in LBCO the current selection, the caret now shows the current selection after the selection knob is pushed.

Magnum Energy Inc.
Tech Service Dept.