



TECH BULLETIN

TECH BULLETIN NUMBER: 0102

DATE: August 26, 2003

Subject: MOV addition

Models affected: All RD and ME Series

Added a 175 Vac MOV (metal oxide varistor) to the ac board as an ac over voltage indicator. This MOV is not for surge protection but a simple means of determining if ac over voltage has been present at the input of the inverter/charger.

Running production change no affect on prior production units.

Magnum Energy Inc.
Tech Service Dept.